

# EV-SAFE DEVICE TEST REPORT

## IDENTIFICATION DATA OF THE TESTED DEVICE

**TRADE NAME:** EV-SaFe  
**SKU CODE:** EVSAFE01  
**SERIAL NUMBER:** 001026  
**MANUFACTURER:** BREMI GmbH  
**DATE OF FIRST ACTIVATION:** 2024-06-17

## IDENTIFICATION DATA OF CALIBRATION EQUIPMENT

**TRADE NAME:** Box-Test EV-SaFe  
**SKU CODE:** EVSTST01  
**SERIAL NUMBER:** 01054  
**MANUFACTURER:** BREMI GmbH  
**DATE OF LAST CALIBRATION:** 2024-12-05

## TESTING LABORATORY

**COMPANY NAME:**

**ADDRESS:**

**CALIBRATION EQUIPMENT:**

**CERTIFICATE Nr.:**

## PRIMARY LABORATORY



**LABORATORY LAT Nr.:** LAT N° 019

**CERTIFICATE REFERENCE:** LAT 019 56717, date of issue: 2019-02-19

## TESTS CARRIED OUT

TEST	PASSED	NOT PASSED	FLASHING LIGHT
TURNING ON EV-SAFE	PASS		NO PASS
A->B TRANSITION TEST		NO PASS	PASS
B->C TRANSITION TEST	PASS		NO PASS
C->D TRANSITION TEST		NO PASS	PASS
C->E TRANSITION TEST	PASS		NO PASS
C->A TRANSITION TEST		NO PASS	NO PASS

*The operator, as a Qualified Technician authorised by the manufacturer, declares that he has carried out the tests in a state-of-the-art manner and in accordance with the manufacturer's most up-to-date instructions.*

## NOTES

**PLACE:**

**DATE:**

05/02/2025

**SIGNATURE OF THE PERSON IN CHARGE:**

**microtronics s.r.l.**  
Via Schiavonia, 93  
31032 Casale sul Sile (TV)  
Italy